



10th January 2014
BJ/SH-L2/7

BSE Limited
Corporate Relationship Department
1st Floor, New Trading Ring
Rotunda Bldg., P J Towers
Dalal Street, Fort
Mumbai 400 001.

National Stock Exchange of India Limited
Exchange Plaza, 5th Floor
Plot No.C/1, Block "G"
Bandra-Kurla Complex
Bandra (East)
Mumbai 400 051.

Dear Sirs,

This is to inform you that late last night (near midnight of 9th January), a loud thud was observed in Low Pressure Turbine accompanied by fire on the turbine and generator deck of the 250 MW Unit 8 at Trombay.

The plant was safely shutdown including safe purging of hydrogen from the generator and safe shutdown of boiler, as the Unit was running with about 185 MW capacity.

NO casualty has occurred nor is any human involved in the event associated with the key plant and equipment.


The extent of damage and reasons for the event shall be ascertained in due course with engineers of Tata Power and OEM experts from BHEL.

The power generation from the rest of the units of Trombay Thermal Power Station remains unaffected.

The Company will ensure that alternate power supply is maintained so that the Mumbai consumers continue to meet their electricity demand.

The Company would like to reiterate its commitment towards safety in and around the plant while ensuring reliable power.

Yours faithfully,
The Tata Power Company Limited


(H. M. Mistry)
Company Secretary

TATA POWER

The Tata Power Company Limited

Registered Office Bombay House 24 Homi Mody Street Mumbai 400 001

Tel 91 22 6665 8282 Fax 91 22 6665 8801